



1-1/4" HOT DIPPED GALVANIZED ROOF NAILS @ 4" (102 mm) O.C. MAX.

ECOWHITE 6" QUICKSEAM FLASHING

SINGLE-PLY QUICKPRIME

CONTINUOUS BEAD OF ECOWHITE LAP SEALANT (SEE NOTE #3)

RUBBERGARD ECOWHITE EPDM MEMBRANE

BONDING ADHESIVE

FIRESTONE INSULATION

SUBSTRATE

WALL

**THIS DETAIL IS APPROVED FOR A MAXIMUM OF 20 YEARS. REFER TO DETAIL EW-RE-14 FOR 25 YEAR REQUIREMENTS.**

**NOTES:**

1. REFER TO FIRESTONE WEBSITE FOR MOST CURRENT INFORMATION.
2. INSTALL METAL WORK TO MANUFACTURER'S REQUIREMENTS OR SMAGNA RECOMMENDATIONS. IF SHOP FABRICATED METAL EDGE IS USED IT MUST MEET ANSISPRI ES-1 OR A FM STANDARD.
3. ECOWHITE LAP SEALANT IS REQUIRED ALONG ENTIRE UPSLOPE EDGE OF ECOWHITE QUICKSEAM FLASHING WHEN ROOF SLOPE IS 1" (25 mm) PER FOOT OR GREATER. REFER TO EW-LS-9 FOR SEAM EDGE TREATMENT.
4. WOOD NAILER MUST BE INSTALLED TO MEET APPLICABLE BUILDING CODES OR 200 LBS PER LINEAR FOOT MINIMUM IN ANY GIVEN DIRECTION.
5. FLANGE METAL MUST BE FULLY SUPPORTED BY WOOD AND TERMINATED AT LEAST 1/2" (13 mm) FROM EDGE OF WOOD.
6. IF THE FLANGE OF THE METAL GUTTER IS NOT COMPLETELY COVERED WITH ECOWHITE QUICKSEAM FLASHING, THEN AN ADDITIONAL PIECE OF ECOWHITE QUICKSEAM FLASHING SHALL BE INSTALLED AT ALL METAL SPLICES REFER TO EW-RE-18.

MAXIMUM WARRANTY: **20 YEARS**

ISSUE /REVISION DATE:

6/06/2014

DETAIL NO.

**EW-RE-13**

**ROOF EDGE WITH FASCIA METAL BY OTHERS**



**Firestone**  
BUILDING PRODUCTS  
**NOBODY COVERS YOU BETTER.™**  
www.firestonebpc.com

ACCEPTABLE SYSTEMS: ADHERED ONLY

NOT TO SCALE