



- NOTES:
1. REFER TO FIRESTONE WEBSITE FOR MOST CURRENT INFORMATION.
 2. REFER TO DETAIL UT-LS-1 OR 2 FOR WELD WIDTH.
 3. COMPRESSIBLE TUBE (SUPPLIED BY OTHERS) DIAMETER MUST EXCEED THE DECK OPENING BY 50% MIN. OR DESIGNED MOVEMENT (WHICH EVER IS GREATER).
 4. BONDING ADHESIVE REQUIRED BETWEEN MEMBRANE AND INSULATION FOR FULLY ADHERED SYSTEM.
 5. MAXIMUM 6" (152 mm) LONG FASTENERS. (NOTE: WOOD BLOCKING MAY BE SUBSTITUTED FOR INSULATION TO REDUCE FASTENER LENGTH REQUIREMENTS.
 6. WHEN REINFORCEMENT OF TPO MEMBRANE IS EXPOSED, REFER TO UT-LS-14 FOR CUT EDGE SEALANT APPLICATION.
 7. REFER TO UT-LS-15 FOR ADDITIONAL LAP SPLICE REQUIREMENTS.

THIS DETAIL IS NOT ACCEPTABLE FOR PAVEMENT BALLAST SYSTEMS. CONTACT FIRESTONE ROOFING SOLUTIONS

Firestone
 BUILDING PRODUCTS
 NOBODY COVERS YOU BETTER.™
 www.firestonebpc.com

EXPANSION JOINT (FIELD FABRICATED) WITH WELDED SPLICE - ROOF TO WALL
 ULTRAPLY™ TPO ACCEPTABLE SYSTEMS: ALL

ISSUE / REVISION DATE:
 7/22/2014
 NOT TO SCALE

MAXIMUM WARRANTY: **20 YEARS**
 DETAIL NO.
UT-E-2