



- NOTES:
1. REFER TO FIRESTONE WEBSITE FOR MOST CURRENT INFORMATION.
 2. REFER TO DETAIL UT-LS-1 OR 2 FOR WELD WIDTH.
 3. WOOD NAILER MUST BE INSTALLED TO MEET APPLICABLE BUILDING CODES OR 200 LBS PER LINEAR FOOT MINIMUM IN ANY GIVEN DIRECTION.
 4. FLANGE OF METAL MUST BE FULLY SUPPORTED BY WOOD AND TERMINATED AT LEAST 1/2" (13 mm) FROM EDGE OF WOOD.
 5. BONDING ADHESIVE REQUIRED BETWEEN MEMBRANE AND INSULATION FOR FULLY ADHERED SYSTEMS. BONDING ADHESIVE REQUIRED BETWEEN METAL MEMBRANE FOR ALL SYSTEMS.
 6. WHEN REINFORCEMENT OF TPO MEMBRANE IS EXPOSED, REFER TO UT-LS-14 FOR CUT EDGE SEALANT APPLICATIONS.

1-1/4" HOT DIPPED GALVANIZED ROOF NAILS @ 6" (152 mm) O.C. MAX.

ULTRAPLY TPO MEMBRANE

WELDED SPLICE (SEE NOTE #2)

ULTRAPLY TPO BONDING ADHESIVE (SEE NOTE #5)

FIRESTONE INSULATION

SUBSTRATE

WALL

1/2" (13 mm) MIN.
1/2" (13 mm) MIN.

WOOD NAILER (SEE NOTE #3)

FIELD CRIMP PER EDGE GARD INSTRUCTIONS.

WATER DAM

FASCIA COVER

1-1/4" HOT DIPPED GALVANIZED ROOF NAILS @ 12" (305 mm) O.C. MAX.

REINFORCING CLIP

MAXIMUM WARRANTY: **20 YEARS**

DETAIL NO.

UT-RE-12

ISSUE / REVISION DATE:

6/25/2014

NOT TO SCALE

ROOF EDGE WITH FIRESTONE EDGE GARD

ULTRAPLY™ TPO

ACCEPTABLE SYSTEMS: ALL

Firestone
BUILDING PRODUCTS
NOBODY COVERS YOU BETTER.™
www.firestonebpc.com