



- NOTES:
1. REFER TO FIRESTONE WEBSITE FOR THE MOST CURRENT INFORMATION.
 2. INSTALL METAL WORK TO FIRESTONE INSTALLATION INSTRUCTIONS.
 3. 9.5" TPO QUICKSEAM MUST EXTEND TO WITHIN 1/4" (6 mm) OF THE GRAVELSTOP RISE.
 4. GP SEALANT IS REQUIRED ALONG FLASHING WHEN ROOF SLOPE IS 1" (25 mm) PER FOOT OR GREATER.
 5. WOOD NAILER MUST BE INSTALLED TO MEET APPLICABLE BUILDING CODES OR 200 LBS PER LINEAR FOOT MINIMUM IN ANY GIVEN DIRECTION.
 6. FLANGE OF METAL MUST BE FULLY SUPPORTED BY WOOD AND TERMINATED AT LEAST 1/2" (13 mm) FROM EDGE OF WOOD.
 7. MECHANICALLY ATTACHED SYSTEMS MUST USE FASTENER AND PLATE OR QUICKSEAM RPF TIE-IN WITH-IN 12" (305 mm) OF GRAVELSTOP.

MAXIMUM WARRANTY: **25 YEARS**

ISSUE / REVISION DATE:

6/25/2014

NOT TO SCALE

DETAIL NO.

UT-RE-21B

ROOF EDGE WITH FIRESTONE UNA-EDGE GS (GRAVEL STOP)

ULTRAPLY™ TPO

ACCEPTABLE SYSTEMS: ALL