



- NOTES:
1. REFER TO FIRESTONE WEBSITE FOR THE MOST CURRENT INFORMATION.
  2. REFER TO DETAIL UT-LS-1 OR UT-LS-2 FOR WELD WIDTH.
  3. REFER TO DETAIL UT-RE-23 FOR ULTRA TPO COATED METAL ROOF EDGE SPLICE.
  4. INSTALL METAL WORK TO SMAGNA RECOMMENDATIONS. IF SHOP FABRICATED METAL EDGE IS USED IT MUST MEET ANSIPRI ES-1 OR AN FM STANDARD.
  5. WOOD NAILER MUST BE INSTALLED TO MEET APPLICABLE BUILDING CODES OR 200 LBS PER LINEAR FOOT MINIMUM IN ANY GIVEN DIRECTION.
  6. FLANGE OF METAL MUST BE FULLY SUPPORTED BY WOOD AND TERMINATED AT LEAST 1/2" (13 mm) FROM EDGE OF WOOD.
  7. ON BALLASTED ROOFS, GRAVEL STOP HEIGHT MUST MEET OR EXCEED BALLAST OR PAVER HEIGHT (2" (51 mm) MIN. ABOVE ROOF SURFACE).
  8. WHEN REINFORCEMENT OF TPO MEMBRANE IS EXPOSED, REFER TO UT-LS-14 FOR CUT EDGE SEALANT APPLICATION.

MAXIMUM WARRANTY: **20 YEARS**

**ROOF EDGE WITH ULTRAPLY TPO COATED METAL**

ULTRAPLY™ TPO

ACCEPTABLE SYSTEMS: ALL

ISSUE / REVISION  
DATE:

6/25/2014

NOT TO SCALE

DETAIL NO.

**UT-RE-22**