



- NOTES:
1. REFER TO FIRESTONE WEBSITE FOR THE MOST CURRENT INFORMATION.
  2. GP SEALANT IS REQUIRED ALONG ENTIRE UPSLOPE EDGE OF QUICKSEAM FLASHING WHEN ROOF SLOPE IS THAN 1" (25 mm) PER FOOT OR GREATER.
  3. WOOD NAILER MUST BE INSTALLED TO MEET APPLICABLE BUILDING CODES OR 200 LBS PER LINEAR FOOT MINIMUM IN ANY GIVEN DIRECTION.
  4. FLANGE OF METAL MUST BE FULLY SUPPORTED BY WOOD AND TERMINATED AT LEAST 1/2" (13 mm) FROM EDGE OF WOOD.

**Firestone**  
 BUILDING PRODUCTS  
 NOBODY COVERS YOU BETTER.<sup>™</sup>  
 www.firestonebpc.com

**ROOF EDGE SPLICE WITH TPO QUICKSEAM FLASHING COVER**

ULTRAPLY<sup>™</sup> TPO ACCEPTABLE SYSTEMS: ALL

ISSUE / REVISION DATE:  
 6/25/2014  
 NOT TO SCALE

DETAIL NO.  
**UT-RE-27**

MAXIMUM WARRANTY: **20 YEARS**