



**WALLS / CURBS  
(MASONRY /  
CONCRETE  
SUBSTRATE  
ONLY)**

**USE APPROPRIATE  
BASE TIE-IN**

- CONTINUOUS BEAD OF AP SEALANT OR HIGH GRADE SEALANT
- CONTINUOUS BEAD OF FIRESTONE WATERBLOCK
- APPROPRIATE FIRESTONE FASTENER 12" (305 mm) O.C. MAX.
- CONTINUOUS BEAD OF AP SEALANT OR ULTRAPLY TPO GP SEALANT
- FIRESTONE TERMINATION BAR
- APPROPRIATE FIRESTONE FASTENER 12" (304,8 mm) O.C. MAX.
- CONTINUOUS BEAD OF FIRESTONE WATERBLOCK
- METAL COUNTERFLASHING BY OTHERS 3" (76 mm) MIN. FACE (SEE NOTE #2 & #3)
- ULTRAPLY TPO MEMBRANE
- ULTRAPLY TPO BONDING ADHESIVE

- NOTES:**
1. REFER TO FIRESTONE WEBSITE FOR MOST CURRENT INFORMATION.
  2. REGULAR MAINTENANCE OF COUNTERFLASHING AND SEALANTS REQUIRED. NOT INCLUDED AS PART OF THE FIRESTONE WARRANTY.
  3. METAL COUNTERFLASHING SHALL BE 24 GAUGE PRE-FINISHED STEEL OR .032" MIN. ALUMINUM FORMED WITH HEMMED LOWER EDGE.
  4. INSTALL FIRESTONE TERMINATION BAR WITH 1/4" (6 mm) GAP BETWEEN ADJOINING SECTIONS.
  5. TERMINATION BAR MUST BE CUT AT INSIDE AND INSIDE CORNERS.  
**DO NOT BEND AROUND CORNERS.**
  6. TERMINATION BAR MUST BE FASTENED WITHIN 1" (25 mm) MAX. OF ALL SECTION ENDS.
  7. INSTALL METAL WORK IN ACCORDANCE WITH CURRENT SMACNA RECOMMENDATIONS.

**MASONRY AND CONCRETE  
WALLS / CURBS MUST BE  
WATERPROOFED AND  
MAINTAINED IN ORDER  
FOR ANY SURFACE  
MOUNTED TERMINATION  
TO BE EFFECTIVE**

**MAXIMUM WARRANTY: 20 YEARS**

**Firestone**  
BUILDING PRODUCTS  
**NOBODY COVERS YOU BETTER.™**  
www.firestonebpc.com

**TERMINATION WITH SURFACE MOUNTED  
COUNTERFLASHING AND TERMINATION BAR**  
ULTRAPLY™ TPO ACCEPTABLE SYSTEMS: ALL

ISSUE / REVISION  
DATE: 7/22/2014  
NOT TO SCALE

DETAIL NO.  
**UT-T-6**