



- NOTES:
1. REFER TO FIRESTONE WEBSITE FOR MOST CURRENT INFORMATION.
 2. NAILING AND METAL COUNTERFLASHING ARE NOT REQUIRED IF MEMBRANE IS RUN UP AND OVER CURB WALLS PRIOR TO INSTALLATION OF R.T.U.
 3. METAL COUNTERFLASHING SHALL BE 24 GAUGE PRE-FINISHED STEEL OR .032" MIN. ALUMINUM FORMED WITH HEMMED LOWER EDGE MOUNTED TIGHTLY TO UNDERSIDE OF MECHANICAL UNIT.
 4. MAXIMUM 6" (152.4 mm) LONG FASTENERS. (NOTE: WOOD BLOCKING MAY BE SUBSTITUTED FOR INSULATION TO REDUCE FASTENER LENGTH REQUIREMENT).
 5. BONDING ADHESIVE REQUIRED BETWEEN MEMBRANE AND INSULATION FOR FULLY ADHERED SYSTEMS.
 6. BATTEN STRIP MAY BE USED IN LIEU OF METAL PLATES FOR MAS AND FULLY ADHERED SYSTEMS ONLY. REFER TO "UT-BT" DETAILS FOR SPECIFIC BASE TIE-IN INFORMATION, REQUIREMENTS, AND OPTIONS.
 7. INSTALL METAL WORK IN ACCORDANCE WITH CURRENT SMACNA RECOMMENDATIONS.

Firestone
 BUILDING PRODUCTS
 NOBODY COVERS YOU BETTER.TM
 www.firestonebpc.com

TERMINATION AT R.T.U. WITH QUICKSEAM RPF AND COUNTERFLASHING (UNIT FLANGE MOUNTED TO SUBST.)
 ULTRAPLYTM TPO ACCEPTABLE SYSTEMS: ALL

ISSUE / REVISION
 DATE: 7/22/2014

MAXIMUM WARRANTY: **20 YEARS**
 DETAIL NO. **UT-T-17**
 NOT TO SCALE