



- NOTES:
1. REFER TO FIRESTONE WEBSITE FOR MOST CURRENT INFORMATION.
 2. REFER TO DETAIL UT-LS-1 OR 2 FOR WELD WIDTH.
 3. MAXIMUM 6" (152 mm) LONG FASTENERS. (NOTE: WOOD BLOCKING MAY BE SUBSTITUTED FOR INSULATION TO REDUCE FASTENER LENGTH REQUIREMENT).
 4. BONDING ADHESIVE REQUIRED BETWEEN MEMBRANE AND INSULATION FOR FULLY ADHERED SYSTEMS.
 5. CONTACT FIRESTONE ROOFING SOLUTIONS FOR BALLASTED ROOF SYSTEMS.
 6. WHEN REINFORCEMENT OF TPO MEMBRANE IS EXPOSED, REFER TO UT-LS-14 FOR CUT EDGE SEALANT APPLICATION.
 7. INSTALL METAL WORK IN ACCORDANCE WITH CURRENT SMACNA RECOMMENDATIONS.

Firestone
 BUILDING PRODUCTS
 NOBODY COVERS YOU BETTER.™
 www.firestonebpc.com

TERMINATION AT SHINGLES
 ULTRAPLY™ TPO
 ACCEPTABLE SYSTEMS: ALL (SEE NOTES)

ISSUE / REVISION
 DATE: 7/22/2014

DETAIL NO.
UT-T-20

MAXIMUM WARRANTY: **20 YEARS**